

Test Report No. 7191245337-MEC20/3B-LNB
dated 30 NOV 2020



PSB Singapore

Add value.
Inspire trust.

Note: This report is issued subject to the Testing and Certification Regulations of the TÜV SÜD Group and the General Terms and Conditions of Business of TÜV SÜD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.

SUBJECT:

Testing on uPVC pipe fittings

TESTED FOR:

SNOW PTE LTD
15A Tuas Ave 18 #03-01
Singapore 638905

Attn : Mr Huang ShengJie

TEST METHOD:

SS 213 : 1998 Specification for Unplasticised PVC pipes and fittings for soil, waste and vent applications.

SAMPLE DESCRIPTION:


The following of "SNOW" Brand UPVC pipe fittings (Socket – Size: 50mm, 100mm and 150mm) were received on 27 October 2020.

TEST LOCATION:

TÜV SÜD PSB Pte Ltd
60 Tuas South Street 1
Singapore 639925

DATE OF TEST:

02 November 2020



LA-2007-0380-A
LA-2007-0381-F
LA-2007-0382-B
LA-2007-0383-G
LA-2007-0384-G
LA-2007-0385-E
LA-2007-0386-C
LA-2010-0464-D
LA-2018-0702-B
LA-2018-0703-G
LA-2020-0747-L

The results reported herein have been performed in accordance with the terms of accreditation under the Singapore Accreditation Council. Inspections/Calibrations/Tests marked "Not SAC-SINGLAS Accredited" in this Report are not included in the SAC-SINGLAS Accreditation Schedule for our inspection body/laboratory.

Laboratory:
TÜV SÜD PSB Pte. Ltd.
No.1 Science Park Drive
Singapore 118221

Phone : +65-6885 1333
Fax : +65-6776 8670
E-mail: enquiries@tuvsud.com
<https://www.tuvsud.com/en-sg>
Co. Reg : 199002667R

Regional Head Office:
TÜV SÜD Asia Pacific Pte. Ltd.
1 Science Park Drive, #02-01
Singapore 118221
TUV®

TEST RESULTS:

(1) Dimensional Measurements of Fittings

Sample Size	Socket			SS 213 : 1998 Requirements		
	50mm	100mm	150mm	50mm	110mm	160mm
Wall thickness	2.8	3.9	4.5	2.4 min	3.2 min	4.0 min
Socket depth	30.7	51.9	76.5	30.1 min	50.8 min	76.2 min
Socket diameter	55.9	110.4	160.3	55.7 min 56.0 max	110.0 min 110.4 max	160.0 min 160.5 max

(2) Stress Relief

Test	Socket			SS 213 : 1998 Requirements
	50mm	100mm	150mm	
Stress Relief at 150°C for 30 min	Comply			Shall comply with Clause 9.2.4

(3) Hydrostatic Pressure


Test	Socket			SS 213 : 1998 Requirements
	50mm	100mm	150mm	
Pressure of 70 kPa for 1 min	Comply			Shall comply with Clause 9.2.3

(4) Opacity

Test	Socket			SS 213 : 1998 Requirements
	50mm	100mm	150mm	
Opacity	Comply			Shall comply with Clause 9.2.6

Note : The results of the softening point and PVC & titanium dioxide tests will be submitted separately


Tan Yong Xiang
Associate Engineer


Lee Ngiap Boon
Senior Associate Engineer
Industrial Group
Mechanical Centre

Test Report No. 7191245337-MEC20/3B-LNB
dated 30 NOV 2020



PSB Singapore

Please note that this Report is issued under the following terms :

1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
2. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, No.1 Science Park Drive Singapore 118221.
6. The tests carried out by TÜV SÜD PSB and this report are subject to TÜV SÜD PSB's General Terms and Conditions of Business and the Testing and Certification Regulations of the TÜV SÜD Group.

Effective 01 September 2020

