

**Test Report No. 7191263930-MEC21/01A-LJY**  
dated 07 OCT 2021



PSB Singapore

**Add value.**  
**Inspire trust.**

**Note:** This report is issued subject to the Testing and Certification Regulations of the TÜV SÜD Group and the General Terms and Conditions of Business of TÜV SÜD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.

**SUBJECT:**

Testing on uPVC pipe fittings

**TESTED FOR:**

SNOW PTE LTD  
15A Tuas Avenue 18  
#03-01 & #04-01  
Singapore 638905

Attn : Mr Huang Sheng Jie

**TEST METHOD:**

SS 272 : 2012 Specification for Unplasticised PVC pipes and fittings below ground for drainlines and sewers

**SAMPLE DESCRIPTION:**

The following nominal size of uPVC fittings were submitted for testing on 10 September 2021.

Nominal Size	Tests Conducted	Painted markings on uPVC fittings submitted
Tee - 110mm Tee - 160mm	1. Dimensional Measurements 2. Hydrostatic Pressure Test 3. Stress Relief	

**TEST LOCATION:**

TÜV SÜD PSB Pte Ltd  
60 Tuas South Street 1  
Singapore 639925



 	LA-2007-0380-A LA-2007-0381-F LA-2007-0382-B LA-2007-0383-G LA-2007-0384-G LA-2007-0385-E	LA-2007-0386-C LA-2010-0464-D LA-2018-0702-B LA-2018-0703-G LA-2020-0747-L	The results reported herein have been performed in accordance with the terms of accreditation under the Singapore Accreditation Council. Inspections/Calibrations/Tests marked "Not SAC-SINGLAS Accredited" in this Report are not included in the SAC-SINGLAS Accreditation Schedule for our inspection body/laboratory.
---	--	--	---

Laboratory:  
TÜV SÜD PSB Pte. Ltd.  
15 International Business Park  
TÜV SÜD @ IBP  
Singapore 609937

Phone : +65-6778 7777  
E-mail: info.sg@tuvsud.com  
<https://www.tuvsud.com/sg>  
Co. Reg : 199002667R

Regional Head Office:  
TÜV SÜD Asia Pacific Pte. Ltd.  
15 International Business Park  
TÜV SÜD @ IBP  
Singapore 609937  
**TUV®**



**DATE OF TEST:**

29 September to 02 October 2021

**TEST RESULTS:**

**Table 1: Dimensional Measurements**

Nominal diameter		Tee 110mm			SS 272 : 2012 Clause 6.3, Table 3 Requirements
					110mm
Socket diameter		110.7			Min. 110.3 , Max. 110.8
Socket Depth		54			Min. 48
Wall thickness (mm)	Readings	3.4	3.5	3.5	Min. 3.1
	Average	3.5			

Nominal diameter		Tee 160mm			SS 272 : 2012 Clause 6.3, Table 3 Requirements
					160mm
Socket diameter		160.5			Min.160.3 , Max. 160.9
Socket Depth		77			Min. 58
Wall thickness (mm)	Readings	4.4	4.4	4.4	Min. 3.7
	Average	4.4			



**TEST RESULTS: (Cont'd)**

**Table 2: Hydrostatic Pressure Test**

Nominal Diameter	110mm	160mm	SS 272 : 2012 Clause 11.1.6, Annex G Requirements
	Tee		
Pressure of 70KPa	Comply		Shall have no leak

**Table 3: Stress Relief**

Nominal Diameter	110mm	160mm	SS 272 : 2012 Clause 11.2.4, Annex H Requirements
	Tee		
Result	Comply		Not penetrate to a depth greater than 50% wall thickness

Lim Jia Yi  
Associate Engineer

Tan Yong Xiang  
Team Leader  
Industrial Group  
Mechanical Centre

**Test Report No. 7191263930-MEC21/01A-LJY**  
**dated 07 OCT 2021**



PSB Singapore

Please note that this Report is issued under the following terms :

1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
2. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, 15 International Business Park TÜV SÜD @ IBP Singapore 609937.
6. The tests carried out by TÜV SÜD PSB and this report are subject to TÜV SÜD PSB's General Terms and Conditions of Business and the Testing and Certification Regulations of the TÜV SÜD Group.

Effective 26 January 2021

