

Test Report No. 7191263930-MEC21/02A-LJY
dated 04 OCT 2021



PSB Singapore

Add value.
Inspire trust.

Note: This report is issued subject to the Testing and Certification Regulations of the TÜV SÜD Group and the General Terms and Conditions of Business of TÜV SÜD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.

SUBJECT:

Testing on uPVC pipe

TESTED FOR:

SNOW PTE LTD
15A Tuas Avenue 18
#03-01 & #04-01
Singapore 638905


Attn : Mr Huang Sheng Jie

TEST METHOD:

SS 272 : 2012 Specification for Unplasticised PVC pipes and fittings below ground for drainlines and sewers

SAMPLE DESCRIPTION:



The following nominal size of uPVC fitting were submitted for testing on 10 September 2021.

Nominal Size	Tests Conducted	Painted markings on uPVC pipes submitted
Tee - 160mm Tee - 110mm	1. Opacity	

DATE OF TEST:

28 September 2021



		LA-2007-0380-A LA-2007-0381-F LA-2007-0382-B LA-2007-0383-G LA-2007-0384-G LA-2007-0385-E	LA-2007-0386-C LA-2010-0464-D LA-2018-0702-B LA-2018-0703-G LA-2020-0747-L	The results reported herein have been performed in accordance with the terms of accreditation under the Singapore Accreditation Council. Inspections/Calibrations/Tests marked "Not SAC-SINGLAS Accredited" in this Report are not included in the SAC-SINGLAS Accreditation Schedule for our inspection body/laboratory.
-------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Laboratory:
TÜV SÜD PSB Pte. Ltd.
15 International Business Park
TÜV SÜD @ IBP
Singapore 609937

Phone : +65-6778 7777
E-mail: info.sg@tuvsud.com
<https://www.tuvsud.com/sg>
Co. Reg : 199002667R

Regional Head Office:
TÜV SÜD Asia Pacific Pte. Ltd.
15 International Business Park
TÜV SÜD @ IBP
Singapore 609937
TUV®



TEST RESULTS:

Table 1: Opacity

Nominal diameter	Tee 110mm	SS 272 : 2012 Clause 11.1.7 Annex I Requirements
Result	(0.0%) Comply	Not more than 0.2%

Table 2: Opacity

Nominal Diameter	Tee 160mm	SS 272 : 2012 Clause 11.1.7 Annex I Requirements
Result	(0.0%) Comply	Not more than 0.2%

Lim Jia Yi
Associate Engineer

Tan Yong Xiang
Team Leader
Industrial Group
Mechanical Centre

Test Report No. 7191263930-MEC21/02A-LJY
dated 04 OCT 2021



PSB Singapore

Please note that this Report is issued under the following terms :

1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
2. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, 15 International Business Park TÜV SÜD @ IBP Singapore 609937.
6. The tests carried out by TÜV SÜD PSB and this report are subject to TÜV SÜD PSB's General Terms and Conditions of Business and the Testing and Certification Regulations of the TÜV SÜD Group.

Effective 26 January 2021

