

Test Report No. 7191372681-CHM26-02-CHY

Date: 21 JAN 2026

Email: Sihai.Li@tuv sud.com

Client's Ref:

Note: This report is issued subject to the Testing, Certification, Validation and Verification Regulations (TCVVR) of the TÜV SÜD Group and the General Terms and Conditions of Business of TÜV SÜD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.



**Add value.
Inspire trust.**

SUBJECT

Evaluation of " 6" Class B PUB Pipe (PUB1506S)" Conformance to Singapore Green Building Council (SGBC) Requirement.

CLIENT

SNOW PTE LTD
15A TUAS AVENUE 18
#03-01 & #04-01
638905
Singapore

DESCRIPTION OF SAMPLE

One sample labelled as follows was received on 02 Dec 2025.

Sample Name	Quantity
6" Class B PUB Pipe (PUB1506S)	1

DATE OF TEST

11 Dec 2025 – 13 Jan 2026



Laboratory:
TUV SÜD PSB Pte. Ltd.
15 International Business Park
TUV SÜD @ IBP
Singapore 609937

Phone : +65-6778 7777
E-mail: info.sg@tuv sud.com
<https://www.tuv sud.com/sg>
Co. Reg : 199002667R

Regional Head Office:
TUV SUD Asia Pacific Pte. Ltd.
15 International Business Park
TUV SÜD @ IBP
Singapore 609937
TUV®



METHOD OF TEST

The sample was tested in the “as-received” condition.

1. Heavy metals analysis of Lead (Pb), Mercury (Hg), and Cadmium (Cd)

The sample was digested by inorganic acid, followed by analysis using Inductively Coupled Plasma Atomic Emission Spectroscopy (ICP-AES).

2. Analysis of Hexavalent Chromium (Cr⁶⁺)

The sample was analysed by UV-Vis spectrometer using 1,5-Diphenylcarbohydrazide as derivatizing agent.

RESULTS

Table 1 : The summary of test results for “6” Class B PUB Pipe (PUB1506S)”:

Test	Result	Method Detection Limit	SGBC Criteria	Inferred Remark
1. Heavy Metals:				
Mercury	Not Detected	0.005%	Less than 0.01%	Pass
Lead	Not Detected	0.005%	Less than 0.009%	Pass
Cadmium	Not Detected	0.005%	Less than 0.01%	Pass
Chromium(VI)	Not Detected	0.005%	Less than 0.01%	Pass

MS CHONG HUI YEE
CHEMIST I

DR LI SIHAI
AVP / SENIOR CHEMIST
CHEMICAL & MATERIALS



Please note that this Report is issued under the following terms :

1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
2. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, 15 International Business Park TÜV SÜD @ IBP Singapore 609937.
6. The tests carried out by TÜV SÜD PSB and this report are subject to TÜV SÜD PSB's General Terms and Conditions of Business and the Testing, Certification, Validation and Verification Regulations (TCVVR) of the TÜV SÜD Group.

Effective 27 March 2024

